



# Laboratory Analysis Report

## 332535

### Lubbock Power & Light




CUSTOMER INFORMATION		ORDER INFORMATION		REPORT AUTHORIZATION	
Address:	Lubbock Power & Light P.O. Box 2000 Lubbock, TX, 79457-0001,	Purchase Order:	710524	Authorized By:	Vernon Glover
Primary Contact:	Carlos Moreno	Submitter Ref:		Email:	VGlover@doble.com
Primary Email:	cmoreno@mylubbock.us	Date Received:	2026-02-27	Date Report Issued:	2026-03-27
		Report Revision:		Authorization Signature:	

Thank you for using Doble Engineering analytical laboratory services, we greatly appreciate the opportunity to serve you and value your business. In accordance with your request, we have performed testing on the sample(s) provided. If the sampling date is not provided, the sample receipt date is used to provide chronological information. Should you have any comments, suggestions or questions please feel free to contact us at the Email listed above.

Samples Requiring Immediate Attention			
Sample Id	Apparatus Type	Serial No	Miscellaneous Id

Doble Engineering and Morgan Schaffer Laboratories are ISO/IEC 17025 Accredited. The analyses contained in this report are based upon material and information supplied by the customer. Doble Engineering/ Morgan Schaffer do not imply that the contents of the sample received are the same as all such material in the environment from which the sample was taken. Our test results only relate to the sample(s) tested. Doble Engineering/ Morgan Schaffer assume no responsibility and makes no warranty or representation as provided in the Doble Terms and Conditions Revision 030232020. This report must not be reproduced, unless in its entirety, without the written consent of Doble Engineering. (^Accredited Tests (from the start date of each lab's accreditation), † Subcontracted Tests, \*Non-Doble/MS Imported Test Results).(\* Subcontracted, † Non-accredited test)

APPARATUS DETAIL				SAMPLING INFORMATION			
	XFMR/TRN S/N:	T101038	LTC Mfgr	Shihlin Electric and Engineering Corp.	Reg Contact Loc:	Syringe No:	Sampled By: Tandan H.
	XFMR Equip. No.:	WA-230-T3	Year Made:	2012	LTC Tank Type:	Misc. ID:	Part Position:
	XFMR/TRN Name:	WA-230-T3	Model:		Liquid Type: Mineral	Work Order:	Top Oil Temp C:
	Substation:	Wadsworth	Compartment:		Volume: 345	Sample Date: 2026-02-26	Humidity:
	LTC S/N		Design Type		Vol Units: Gallons	Sample Time:	Amb Temp C:
	LTC Equip. No.	WA-230-T3	LTC Type	1331670		Report Type: LTC-SINGLETANK	

Sample Id: 332535-016      Serial Number: T101038      Misc Id:

Miscellaneous Tests		
	Sample Date:	2026-02-26
	Analysis Date:	2026-03-24
	Doble Sample Id:	332535-016
	Top Oil Temperature:	
PCB Content	D4059(ppm)	< 1
Aroclor Detected		ND

Comments: This sample is considered to be 'Non-PCB' (<50 ppm) per EPA regulations listed in 40 CFR part 761.