



Laboratory Analysis Report

333312

Lubbock Power & Light




CUSTOMER INFORMATION		ORDER INFORMATION		REPORT AUTHORIZATION	
Address:	Lubbock Power & Light P.O. Box 2000 Lubbock, TX, 79457-0001,	Purchase Order:	710524	Authorized By:	Vernon Glover
Primary Contact:	Carlos Moreno	Submitter Ref:		Email:	VGlover@doble.com
Primary Email:	cmoreno@mylubbock.us	Date Received:	2026-03-16	Date Report Issued:	2026-03-24
		Report Revision:		Authorization Signature:	

Thank you for using Doble Engineering analytical laboratory services, we greatly appreciate the opportunity to serve you and value your business. In accordance with your request, we have performed testing on the sample(s) provided. If the sampling date is not provided, the sample receipt date is used to provide chronological information. Should you have any comments, suggestions or questions please feel free to contact us at the Email listed above.

Samples Requiring Immediate Attention			
Sample Id	Apparatus Type	Serial No	Miscellaneous Id

Doble Engineering and Morgan Schaffer Laboratories are ISO/IEC 17025 Accredited. The analyses contained in this report are based upon material and information supplied by the customer. Doble Engineering/ Morgan Schaffer do not imply that the contents of the sample received are the same as all such material in the environment from which the sample was taken. Our test results only relate to the sample(s) tested. Doble Engineering/ Morgan Schaffer assume no responsibility and makes no warranty or representation as provided in the Doble Terms and Conditions Revision 030232020. This report must not be reproduced, unless in its entirety, without the written consent of Doble Engineering. (^Accredited Tests (from the start date of each lab's accreditation), † Subcontracted Tests, *Non-Doble/MS Imported Test Results).(* Subcontracted, † Non-accredited test)

APPARATUS DETAIL				SAMPLING INFORMATION			
	Serial Number:	6531303	Cooling:	Temp Rise C:	65	Syringe No:	Sampled By: Tandan H.
	Equipment No.:	SRT2	Max KV: 4.687	Preservation:	Gas Blanketed	Misc. ID:	Part Position: Bottom
	XFMR/TRN Name:	SRT2	Max MVA:	Liquid Type:	Mineral	Work Order:	Top Oil Temp C:
	Substation:	Sears	XFMR/TRN Type: XFMR	Volume:	1938	Sample Date: 2026-03-16	Humidity:
	Manufacturer:	Westinghouse ABB	Design Type: Core Type	Vol Units:	Gallons	Sample Time:	Amb Temp C:
	Year Made:		1 or 3 Phase: No			Report Type: XFMR-Bottom	

Sample Id: 333312-005 Serial Number: 6531303 Misc Id:

Miscellaneous Tests			
	Sample Date:	2026-03-16	2022-08-05
	Analysis Date:	2026-03-24	2022-08-19
	Doble Sample Id:	333312-005	272241-014
	Top Oil Temperature:		55
PCB Content	D4059(ppm)	10	9
Aroclor Detected		1260	1260

Comments: This sample is considered to be 'Non-PCB' (<50 ppm) per EPA regulations listed in 40 CFR part 761.